

GUIDE YVL C.3

LIMITATION AND MONITORING OF RADIOACTIVE RELEASES FROM A NUCLEAR FACILITY

1	Introduction	3
2	Scope for application	5
3	Limitations concerning radiation exposure and releases	7
3.1	General requirements	7
3.2	Design limitations	8
3.2.1	Normal operation and anticipated operational occurrences	8
3.2.2	Accidents	8
3.3	Operational limits	9
3.3.1	Release limits	9
3.3.2	Releases requiring action	10
3.3.3	Planned releases	10
3.3.4	Target levels for releases	10
4	Special systems for reducing releases	12
5	Requirements for release measurements	13
5.1	General requirements	13
5.2	Measuring of releases from a nuclear power plant during normal operation	14
5.2.1	Airborne releases	14
5.2.1.1	Radioactive noble gases	14
5.2.1.2	Radioactive iodine	15
5.2.1.3	Other radioactive substances	15
5.2.2	Waterborne releases	16
5.3	Measuring of abnormal releases from a nuclear power plant	16
5.3.1	Airborne releases	16
5.3.2	Waterborne releases	17
6	Regulatory oversight by the Radiation and Nuclear Safety Authority	18
7	ANNEX Summary of the release measurements from a nuclear power plant during normal operation	20
8	References	22

Definitions

Authorisation

According to Section 7 r of the Nuclear Energy Act (990/1987), *the Radiation and Nuclear Safety Authority (STUK) shall specify detailed safety requirements for the implementation of the safety level in accordance with the Nuclear Energy Act.*

Rules for application

The publication of a YVL Guide shall not, as such, alter any previous decisions made by STUK. After having heard the parties concerned STUK will issue a separate decision as to how a new or revised YVL Guide is to be applied to operating nuclear facilities or those under construction, and to licensees' operational activities. The Guide shall apply as it stands to new nuclear facilities.

When considering how the new safety requirements presented in the YVL Guides shall be applied to the operating nuclear facilities, or to those under construction, STUK will take due account of the principles laid down in Section 7 a of the Nuclear Energy Act (990/1987): *The safety of nuclear energy use shall be maintained at as high a level as practically possible. For the further development of safety, measures shall be implemented that can be considered justified considering operating experience, safety research and advances in science and technology.*

According to Section 7 r(3) of the Nuclear Energy Act, *the safety requirements of the Radiation and Nuclear Safety Authority (STUK) are binding on the licensee, while preserving the licensee's right to propose an alternative procedure or solution to that provided for in the regulations. If the licensee can convincingly demonstrate that the proposed procedure or solution will implement safety standards in accordance with this Act, the Radiation and Nuclear Safety Authority (STUK) may approve a procedure or solution by which the safety level set forth is achieved.*

With regard to new nuclear facilities, this Guide shall apply as of 1 April 2019 until further notice. With regard to operating nuclear facilities and those under construction, this Guide shall be enforced through a separate decision to be taken by STUK. This Guide replaces Guide YVL C.3 (15.11.2013).

Translation. Original text in Finnish.

STUK • SÄTEILYTURVAKESKUS
STRÅLSÄKERHETSCENTRALEN
RADIATION AND NUCLEAR SAFETY AUTHORITY

Osoite / Address • Laippatie 4, 00880 Helsinki

Postiosoite / Postal address • PL / P.O.Box 14, FI-00811 Helsinki, FINLAND

Puh. / Tel. (09) 759 881, +358 9 759 881 • Fax (09) 759 88 500, +358 9 759 88 500 • www.stuk.fi

1 Introduction

101. The operation of a nuclear power plant and other nuclear facility may expose the surrounding population to radiation as a result of radioactive releases and direct radiation emitted from the plant. In order to minimise the radiation exposure of the surrounding population, the radiation exposure caused by the normal operation of and potential operational occurrences and accidents in a nuclear facility is restricted. [2013-11-15]

102. Exhaust air from the nuclear facility ventilation and gaseous substances diverted from processes, cleaned where necessary, are released to the atmosphere in normal operation. Cleaned effluent waters from plant processes are discharged into the aquatic environment. In terms of normal releases, the significant release pathways are for example the vent stack and the outlet water channel. In transients and accidents, radioactive substances may also find their way into the environment via exceptional pathways, and the composition of the releases may be different from normal. The releases are monitored by means of process and release measurements carried out inside the facility on the one hand, and by observing the radiation and radioactive substances present in the environment on the other. [2019-03-15]

103. The provisions regulating the use of nuclear energy are laid down in the Nuclear Energy Act (990/1987) and the Nuclear Energy Decree (161/1988) issued thereunder. According to Section 6 of the Nuclear Energy Act, *the use of nuclear energy must be safe; it shall not cause injury to people, or damage to the environment or property.* [2019-03-15]

104. General provisions for limiting radiation exposure are laid down in the Radiation Act (859/2018) and Government Decree on Ionising Radiation (1034/2018). The provisions of Chapter 2 (General principles of radiation protection) Sections 5 -7 and Chapter 9 (Radiation measurements) of the Radiation Act also apply to the use of nuclear energy. [2019-03-15]

105. According to Chapter 2 Sections 5 -7 of the Radiation Act (859/2018), the use of radiation and practices involving radiation exposure shall meet the following requirements so as to be considered acceptable:

1. *The benefits derived from the practice shall exceed the detriment it causes (principle of justification).*
2. *The practice shall be arranged so that the resulting exposure to radiation hazardous to health is kept as low as is reasonably achievable (principle of optimisation).*
3. *No person shall be exposed to radiation exceeding the maximum values prescribed by Decree (principle of limitation).* [2019-03-15]

106. According to Section 7 c of the Nuclear Energy Act (990/1987), *the maximum values of radiation exposure caused by a nuclear facility or any other use of nuclear energy on any member of the public will be provided for by Government decree. Limits on releases of radioactive materials from a nuclear facility, in order that they do not exceed the maximum values for radiation exposure provided by Government decree, shall be confirmed by STUK. Supervision of releases of radioactive materials shall be arranged so that compliance with limits as referred to in this section can be reliably established.* These release limits are specified in the Operational Limits and Conditions of the nuclear facility approved by STUK. Based on the measurement results, steps may be taken to reduce the releases where necessary.

[2019-03-15]

107. The Radiation and Nuclear Safety Authority Regulation on the Safety of a Nuclear Power Plant (STUK Y/1/2018) presents the general safety provisions for nuclear power plants, and Section 24 of the regulation presents the requirements for radiation measurements and monitoring of releases of radioactive substances and assessment of radiation doses to the public. Chapter 3 of this regulation includes the requirements for radiation exposure and releases of radioactive substances. Regulation STUK Y/4/2018 presents the provisions concerning the safety of disposal of nuclear waste, which also apply to separate processing and storage facilities for nuclear waste that are not a part of a nuclear power plant. The principles laid down in Chapter 2 of the Radiation Act have been observed in drafting the regulations.

[2019-03-15]

108. According to the Commission Recommendation on the application of Article 37 of the Euratom Treaty (2010/635/Euratom), the Member States shall provide the Commission with information about the estimated environmental impacts of the use of nuclear energy. For example, the data pertaining to a nuclear power plant shall be submitted whenever possible one year, but no later than six months, prior to the issuance of an operating licence. [2013-11-15]

2 Scope for application

201. The present Guide provides detailed requirements to be satisfied by the applicant and licensee regarding the reduction of radioactive releases from a nuclear power plant as well as the radiation measurements, sampling systems and laboratory determinations used for monitoring the radioactive releases from the plant. Additionally, design requirements are specified, particularly for systems designed for limiting releases. Where applicable, the requirements specified in the Guide shall also apply to research reactors and other nuclear facilities, in accordance with their application decisions.

However, equivalent requirements for nuclear facilities related to nuclear waste handling and nuclear waste management are specified in Guides YVL D.3 "Handling and storage of nuclear fuel", YVL D.4 "Predisposal management of low and intermediate level nuclear waste and decommissioning of a nuclear facility", and YVL D.5 "Disposal of nuclear waste", in which reference is made to this Guide as applicable. [2019-03-15]

202. This Guide applies to the design, construction, commissioning and use of a nuclear facility. The Guide applies to normal operation as well as operational occurrences and accidents. The decommissioning of nuclear facilities is governed by Guide YVL D.4. [2019-03-15]

203. The requirements concerning the structural radiation safety and radiation monitoring systems and equipment of nuclear facilities are specified in Guide YVL C.1 "Structural radiation safety at a nuclear facility" and Guide YVL C.6 "Radiation monitoring at a nuclear facility". [2019-03-15]

204. The requirements concerning the assessment of the dispersion of radioactive releases and the radiation doses received by the local population as well as the monitoring of the radiation and radioactive substances present in the environment are specified in Guide YVL C.4 "Assessment of radiation doses to the public in the vicinity of a nuclear facility". The requirements concerning the radiological monitoring of the environment are specified in the Guide YVL C.7 "The Radiological monitoring of the environment of a nuclear facility". A comprehensive discussion of the analysis of transients and accidents of a nuclear power plant is provided in Guide YVL B.3 "Deterministic safety analyses for a nuclear power plant", while probabilistic risk assessment is discussed in Guide YVL A.7 "Probabilistic risk assessment and risk management of a nuclear power plant". The reporting to STUK concerning offsite radiation safety, including the reporting of releases, is detailed in Guide YVL A.9 "Regular reporting on the operation of a nuclear facility". The requirements concerning the laboratory functions of a nuclear power plant as well as the radiochemical measurements of the primary and the

secondary circuit are specified in Guide YVL B.5 "Reactor coolant circuit of a nuclear power plant". The preliminary and final safety analysis reports for a nuclear facility are discussed in Guide YVL A.1 "Regulatory oversight of safety in the use of nuclear energy "and the Operational Limits and Conditions in Guide YVL A.6 "Conduct of operations at a nuclear power plant". [2019-03-15]

3 Limitations concerning radiation exposure and releases

3.1 General requirements

301. The radiation exposure arising from the operation of a nuclear facility shall be kept as low as reasonably achievable. A nuclear facility and its operation shall also be so designed that the constraints specified in the Nuclear Energy Decree (161/1988) are not exceeded. Hence, mere compliance with the constraints is not enough; instead, efforts shall be made to keep the radioactive releases to and radiation levels in the environment arising from the operation of the plant as low as reasonably achievable. [2019-03-15]

302. According to Section 7 a of the Nuclear Energy Act (990/1987), *the safety of nuclear energy use shall be maintained at as high a level as practically possible. For the further development of safety, measures shall be implemented that can be considered justified considering operating experience, safety research and advances in science and technology.* The limitation of radioactive releases to and radiation levels in the environment shall be implemented by employing the best available techniques. [2019-03-15]

303. The documents to be submitted to STUK pursuant to Guide YVL A.1 when filing the application for a decision-in-principle of a nuclear facility shall specify the principles according to which the limitation and monitoring of radioactive releases is intended to be arranged. The documents shall also present an estimate of the anticipated releases both during normal operation and in anticipated operational occurrences and accidents. [2013-11-15]

304. In the preliminary and final safety analysis reports of the nuclear facility pursuant to Guide YVL A.1, the applicant and licensee shall present an analysis of the radioactive releases and radiation exposure of the population arising from the normal operation of and anticipated operational occurrences and accidents in the facility. The reports must also demonstrate that the radiation exposure arising from the operation of a facility is as low as reasonably achievable and that radioactive releases to and radiation levels in the environment are limited by employing the best available techniques. [2019-03-15]

3.2 Design limitations

3.2.1 Normal operation and anticipated operational occurrences

305. Section 22 b of the Nuclear Energy Decree (161/1988) stipulates that *the constraint for the annual dose of an individual in the population, arising from the normal operation of a nuclear power plant or another type of nuclear facility equipped with a nuclear reactor, is 0.1 millisievert, and the constraint for the annual dose of an individual in the population, arising as the result of an anticipated operational occurrence, is 0.1 millisievert.* The constraints concern the annual dose received by the representative person of the most highly exposed population group.

[2019-03-15]

306. The applicant and licensee shall analyse the magnitude of the effective doses received by the representative person in the most highly exposed population group arising from normal operation and anticipated operational occurrences. The collective doses to the population shall also be analysed. All activities that take place on the plant site shall be considered when calculating the collective doses arising from the normal operation of a nuclear facility. These include the treatment and intermediate storage of power plant operational waste, the operation of the final disposal facility, and the intermediate storage of spent nuclear fuel. [2019-03-15]

3.2.2 Accidents

307. Section 22 b of the Nuclear Energy Decree (161/1988) stipulates, in respect of accidents at nuclear power plants and other types of nuclear facilities equipped with a nuclear reactor, that *the constraint for the annual dose received by an individual in the population as a result of a release is:*

- 1 mSv for Class 1 postulated accidents;
- 5 mSv for Class 2 postulated accidents; and
- 20 mSv for a design extension condition. [2019-03-15]

308. The constraints concern the annual dose received by the representative person of the most highly exposed population group. [2019-03-15]

309. Section 22 b of the Nuclear Energy Decree (161/1988) stipulates that *at a nuclear power plant the release of radioactive substances arising from a severe accident shall not necessitate large scale protective measures for the population nor any long-term restrictions on the use of extensive areas of land and water.*

In order to limit the long term effects, the limit for atmospheric releases of cesium-137 is 100

terabecquerel. The possibility of exceeding the set limit shall be extremely small.

The possibility of a release in the early stages of an accident requiring measures to protect the population shall be extremely small. [2019-03-15]

310. When a nuclear power plant is designed, analyses must be provided to demonstrate that any release of radioactive substances in a severe accident shall not warrant the evacuation of the population beyond the protective zone or the need for people beyond the emergency planning zone to seek shelter indoors and that any cesium-137 (Cs-137) release is less than the limit value 100 TBq specified for it. [2019-03-15]

311. Guide YVL A.7 specifies a limit value for the frequency of occurrence for accidents involving a Cs-137 release exceeding 100 TBq and a limiting requirement for losing the containment function in severe reactor accidents in order to limit the occurrence frequency of a release requiring measures to protect the population in early stages. [2013-11-15]

312. The applicant and licensee shall analyse the magnitude of the effective doses received by the representative person of the most highly exposed population group, and the magnitude of the collective doses to the population arising from accidents. [2013-11-15]

312a. The extent and duration of soil and water contamination arising from a severe reactor accident shall also be analysed. [2019-03-15]

3.3 Operational limits

3.3.1 Release limits

313. The applicant and licensee shall derive limits for the release of radioactive substances from the nuclear power plant (the nuclear power plant units located on the same plant site and other nuclear facilities) in such a way that the constraint for the dose to an individual as defined in Section 22 b of the Nuclear Energy Decree (161/1988) is not exceeded. [2019-03-15]

314. The applicant and licensee shall separately define release limits for the most important radionuclide groups or radionuclides in terms of radiation exposure. When the limits are derived, all significant radionuclides and release pathways shall be considered, up-to-date models and parameters based on theoretical and practical knowledge shall be employed and sufficient safety margins applied. [2013-11-15]

315. The release limits shall be defined in view of releases occurring over a period of one year. If the radiation monitoring of the environment indicates that the radiation dose of an individual in the population may exceed the dose constraints, the release limits shall be redefined.

[2019-03-15]

316. According to Guide YVL A.6, the applicant and licensee shall specify the release limits in the Operational Limits and Conditions of the plant. [2019-03-15]

3.3.2 Releases requiring action

317. In the event that the release rate exceeds the threshold values specified below, the licensee shall take action to reduce the releases when this occurs, if not earlier. Any exceedance of the threshold value or other significant increase in the release rate shall be reported to STUK as provided in Guide YVL A.9. [2013-11-15]

318. The reporting threshold is $5 \times$ the steady release rate consistent with the release limit (averaged over a maximum period of one week). [2013-11-15]

319. The release threshold requiring corrective action to be taken is $3 \times$ the steady release rate consistent with the release limit (averaged over a maximum period of one month).

[2013-11-15]

320. The operation of the nuclear facility shall be limited as provided in the Operational Limits and Conditions if, based on releases or environmental radiation monitoring measurements, it is evident that the release limits defined in the Operational Limits and Conditions would otherwise be exceeded. [2013-11-15]

3.3.3 Planned releases

321. The licensee shall provide STUK with a prior notification of any planned abnormal releases exceeding the reporting threshold referred to in requirement 318. [2013-11-15]

3.3.4 Target levels for releases

322. In addition to the release limits discussed in section 3.3.1, the licensee shall, as laid down in requirements 301 and 302, determine, representing continuous improvement of operations and good operation of the plant and its personnel, target values which the licensee aims not to exceed for the annual releases of radioactive substances of the nuclear facility and the radiation doses received by the representative person in the most highly exposed population group. The release target values can be specified for groups of elements and the most important radionuclides and described, for example, in the plant's radiation protection guidelines. The

target values shall be updated at appropriate intervals. Performance in attaining the release target values shall be evaluated and the plans necessary for such attainment presented in the annual report on radiation safety to be filed with STUK as provided in Guide YVL A.9.

[2013-11-15]

4 Special systems for reducing releases

401. The applicant and licensee shall design the systems and components containing radioactive substances in such a way that releases of radioactive substances and the radiation exposure of the population living in the vicinity of the plant can be kept low as provided in requirements 301 and 302. The release pathways of radioactive substances shall be identified, and systems to effectively reduce releases shall be designed for collecting and purifying liquids and gases containing radioactive substances. Different radionuclides shall be accounted for in the design of the systems. [2013-11-15]

402. Releases can be reduced by means of various methods designed for the treatment of radioactive substances. The methods for treating liquids include mechanical filtration, ion exchange, centrifugation, evaporation, and chemical precipitation. The treatment method employed shall be suitable for the type and amount of contamination present in the liquid. While applying requirements 301 and 302 to decreasing the releases of radioactive substances, the licence applicant and the licensee must, in addition to the radiation exposure caused by the releases, take into account the radiation exposure caused by the purification of the releases and the management and disposal of the resulting solid waste. Final disposal is addressed in Guide YVL D.5. [2019-03-15]

403. Adequate delay systems for off-gases shall be provided to reduce the releases of noble gases. The gas treatment and ventilation systems of the plant shall be fitted with effective particle filters and activated carbon filters to reduce radioactive aerosol and iodine releases. A more detailed discussion of the ventilation systems of a nuclear facility is provided in Guide YVL B.1. [2019-03-15]

5 Requirements for release measurements

5.1 General requirements

501. According to Section 24 of Radiation and Nuclear Authority Regulation STUK Y/1/2018, the radiation levels of nuclear facility rooms and the activity concentrations of indoor air and the gases and liquids in the systems shall be measured, releases of radioactive substances from the plant monitored, and concentrations in the environment controlled. [2019-03-15]

502. The licensee shall monitor the releases of radioactive substances from the nuclear facility by means of adequate measurements. The sensitivity of the release measurements performed at a nuclear power plant shall be such as to allow the reliable measurement of any releases that could expose the representative person in the most highly exposed population group to radiation in the amount that only accounts for a small fraction of the radiation exposure equalling the constraint (0.1 mSv/a) prescribed in Section 22 b of the Nuclear Energy Decree (161/1988). The methods employed shall be so selected that the overall reliability, representativeness, sensitivity and accuracy of the measurements are as high as achievable with available advanced techniques. The release measurement equipment shall be located in rooms where the background radiation will not interfere with the measurements. Examples of detection limits that can be achieved or beaten are given in the annex to this Guide.

[2019-03-15]

503. The requirements pertaining to the laboratory functions and its activity measuring instruments specified in Guides YVL B.5 and YVL C.6 also apply to the handling, analysis and measuring of release samples. [2019-03-15]

504. In the preliminary and final safety analysis reports of the nuclear facility, the applicant and licensee shall present in accordance with Guide YVL A.1 an analysis of the transport of radioactive substances in plant systems (e.g. mass balances and transport diagrams) as well as a description of release pathways and the radiation and release monitoring of the pathways.

[2013-11-15]

505. The preliminary safety analysis report shall contain a description of the analyses and tests that have been or will be carried out to demonstrate the performance of the release measurement systems, including the representativeness of sampling. These analyses and a summary of the test results shall be presented in the final safety analysis report. [2019-03-15]

5.2 Measuring of releases from a nuclear power plant during normal operation

5.2.1 Airborne releases

506. The licensee shall monitor the significant release pathways of radioactive substances into the atmosphere (e.g. vent stack) by means of stationary and continuously-operating radiation monitoring systems. It shall also be possible to monitor the release pathways in the event of a single failure occurring in the systems. [2013-11-15]

507. Since it is not possible to determine with sufficient accuracy all airborne radioactive releases by means of direct release measurement in the flow channel (e.g. vent stack), the applicant and licensee shall arrange a sample flow and sampling into a dedicated sampling and measuring system from the release flow whenever necessary. Redundancy shall be provided for continuously operating radiation monitoring systems and equipment designed for the monitoring of radioactive releases (flow lines with pumps or valves, radiation monitoring equipment, sampling filters, sampling rakes, etc.) in accordance with Guide YVL C.6. Sampling from the release flow shall be representative in such a way that account is taken of all radioactive substances in gaseous and other forms (aerosols, particles). [2019-03-15]

508. The licensee shall be capable of reliably determining the volumetric flow rate of gas within the vent stack or other significant points of release in all conditions. [2019-03-15]

509. By way of an exception, the releases may also be determined by other means if direct measuring or representative sampling is difficult to accomplish. Examples include the releases arising from a leak or discharge of water or steam from the secondary circuit of a pressurised water reactor that may be determined, for example, based on the radionuclide content of the water in the primary or secondary circuit and the analysis of the amounts of water removed from the secondary circuit. [2013-11-15]

5.2.1.1 Radioactive noble gases

510. The licensee shall measure the releases of noble gases by means of a stationary, continuously-operating radiation monitoring system that may be gamma-spectrometric or of the type that measures the total gamma or total beta activity. It shall also be possible to take a gas sample for laboratory determination purposes. The releases shall be determined based on the results of the monitoring system and the sampling-based radionuclide analysis performed in a laboratory at regular intervals. [2013-11-15]

511. Significant noble gas nuclides in the release line shall be determined by gamma-spectrometric means in a laboratory on a weekly basis, if not more frequently, and in a representative manner in situations where the composition or rate of the release has or is suspected of having undergone essential changes. [2019-03-15]

5.2.1.2 Radioactive iodine

512. The licensee shall collect a representative sample of the releases on an on-going basis using filters with sufficient separating capacity to trap inorganic and organic iodine compounds. The filters shall be replaced and a gamma-spectrometric radionuclide analysis shall be performed on them in a laboratory on a weekly basis, if not more frequently, and in a representative manner in situations where the composition or amount of the releases has or is suspected of having undergone changes. [2013-11-15]

513. The releases of radioactive iodine through the vent stack of a nuclear power plant shall also be measured by means of a stationary, continuously-operating radiation monitoring system based on the measurement of the activity of iodine-131 (I-131) contained in the sample that is collected in the filter on a continuous basis. This system does not need to meet the single failure criterion. [2019-03-15]

5.2.1.3 Other radioactive substances

514. The licensee shall collect a representative sample of the releases on an on-going basis using a particulate air filter with sufficient separating capacity. The filter shall be replaced and a gamma-spectrometric radionuclide analysis shall be performed on it in a laboratory on a weekly basis, if not more frequently, and in a representative manner also in situations where the composition or rate of the release has or is suspected of having undergone changes. In this connection, the radioactive iodine isotopes accumulated in the filter shall also be determined where necessary. The total activity of alpha-emitting nuclides shall also be determined from the sample combined from the filters on a monthly basis, if not more frequently. The most important alpha-emitting nuclides shall be analysed in the event of increased total activity of the alpha-emitting nuclides. Amounts of the radionuclides strontium-89 (Sr-89) and strontium-90 (Sr-90) shall be analysed from a composite sample on a quarterly basis. [2019-03-15]

515. Tritium (H-3) and carbon-14 (C-14) shall be determined from a representative sample continuously collected from the release on a monthly basis, if not more frequently, and in a representative manner also in situations where the release rate has or is suspected of having

undergone essential changes. These samplings do not need to meet the single failure criterion and can be assigned to Class EYT. [2019-03-15]

516. The releases of radioactive aerosols through the vent stack of a nuclear power plant shall also be measured by means of a stationary, continuously-operating radiation monitoring system based on the measurement of the total gamma or total beta activity contained in the sample that is collected in the filter on a continuous basis. This system does not need to meet the single failure criterion. [2019-03-15]

5.2.2 Waterborne releases

517. The licensee shall monitor the significant release pathways of radioactive substances into the aquatic environment by means of stationary and continuously-operating radiation monitoring systems. It shall also be possible to monitor the release pathways in the event of a single failure occurring in the radiation monitoring systems as provided in Guide YVL C.6. [2019-03-15]

518. A representative sample shall always be taken of any liquid releases. For any significant release pathways, samples shall be taken beforehand separately for each release batch and a representative sample shall be automatically taken from the release line. A gamma-spectrometric radionuclide analysis shall be performed on the release samples in a laboratory. Additionally, the activity of tritium (H-3) and the total activity of alpha-emitting nuclides shall be determined from a composite sample representing the total release over a period of one month. The most important alpha-emitting nuclides shall be analysed in the event of increased total activity of the alpha-emitting nuclides. Radionuclides Sr-89 and Sr-90 shall be analysed on a quarterly basis from a sample representing total releases of the period. [2019-03-15]

5.3 Measuring of abnormal releases from a nuclear power plant

5.3.1 Airborne releases

519. The licensee shall also be capable of determining the airborne radioactive releases in all operational occurrences and accidents by means of stationary, continuously-operating radiation monitoring systems and based on sampling and laboratory analysis. Both the sampling and the measuring arrangements and operations shall be so accomplished that sufficient data on the releases of radioactive substances can be obtained with considerable certainty even in the event of a severe accident. These systems shall meet the single failure criterion as provided in Guide YVL C.6. [2019-03-15]

520. To enable timely detection of exceptional releases, the processes of a nuclear power plant shall be monitored by means of stationary radiation measuring instruments. The requirements pertaining to these instruments are specified in Guide YVL C.6. Additionally, the amount of radioactive substances present in the primary circuit, in the exhaust gas from the turbine condenser of a boiling water reactor plant, and in the water of the secondary circuit of a pressurised water reactor plant shall be monitored by means of sampling and laboratory analyses. [2013-11-15]

5.3.2 Waterborne releases

521. The continuously-operating radiation monitoring system that monitors the waterborne releases from a nuclear power plant shall automatically and reliably shut off the release line concerned if the measured activity exceeds the maximum limit set for the activity in the release line or if the monitoring systems fails. This system shall meet the single failure criterion as provided in Guide YVL C.6. [2019-03-15]

522. In addition to the radiation monitoring systems, exceptional release pathways (various intermediate circuits, the secondary circuit of a pressurised water reactor) shall also be monitored by means of adequate sampling systems and laboratory determinations. [2013-11-15]

6 Regulatory oversight by the Radiation and Nuclear Safety Authority

601. When the application for a decision-in-principle is filed, STUK will assess based on the documents submitted directly to STUK in accordance with Guide YVL A.1 whether the nuclear facility concerned fulfils the necessary preconditions for satisfying the requirements for limiting and monitoring of radioactive releases prescribed by law and the YVL Guides. [2013-11-15]

602. STUK will check from the preliminary and final safety analysis report and the accompanying separate reports pertaining to the nuclear facility concerned that the requirements specified in chapters 3 through 5 in this Guide are met. [2019-03-15]

603. STUK will check that the Operational Limits and Conditions of the nuclear facility contain the release limits specified in section 3.3.1 and that these limits are acceptable. Additionally, STUK will make an assessment of the target values for releases discussed in section 3.3.4. [2013-11-15]

604. The regulatory oversight of the radiation monitoring systems and equipment used for measuring the releases of radioactive substances from a nuclear facility is discussed in Guide YVL C.6. [2013-11-15]

605. During the construction of a nuclear facility, STUK will assess and verify that the systems necessary for limiting and monitoring of releases of radioactive substances are implemented in compliance with the plans and designs presented to STUK. The licensee's performance is evaluated in on-site inspections carried out in accordance with the construction inspection programme. [2013-11-15]

606. During the operation of the nuclear facility, STUK will oversee the radioactive releases and radiation levels in the environment by observing the release measurements, the dose analyses derived from these results and the environmental radiation monitoring performed by the licensee as provided in this Guide as well as Guides YVL C.4 and C.7. The oversight of the release measurements and environmental radiation monitoring by STUK will be carried out by checking the measurement results reported to STUK as provided in Guide YVL A.9.

Additionally, STUK will make an assessment of the measures required to attain the target levels for releases as defined in section 3.3.4. STUK also controls the release measurements and environmental radiation monitoring by inspecting any repairs and modifications to the radiation monitoring systems and equipment, and by auditing the steps taken by the licensee to ensure reliable measurements. The actions of the licensee are assessed by means of inspections specified in the periodic inspection programme and, where necessary, by means of other

on-site inspections. [2019-03-15]

607. STUK will continue to oversee the monitoring of radioactive releases from the nuclear facility throughout the decommissioning of the facility, until the nuclear facility has been finally dismantled and all the dismantling waste packed and disposed of. Decommissioning is addressed in Guide YVL D.4. [2019-03-15]

7 ANNEX Summary of the release measurements from a nuclear power plant during normal operation

A01. Table: Summary of the measurements of normal gaseous and particulate releases from a nuclear power plant and examples of radionuclides present in the releases complete with detection limits that can be achieved or beaten at low total activities.

Release type	Measuring procedure	Redundancy	Radionuclide	Detection limit in release flow
noble gases	continuous measurement	yes	^{133}Xe	10 kBq/m ³ during the measuring period < 10 min
	laboratory determination weekly, if not more frequently	yes	^{85}Kr	10 kBq/m ³
			^{87}Kr	1 kBq/m ³
			^{133}Xe	1 kBq/m ³
iodine	continuous measurement		^{131}I	2 Bq/m ³ during the measuring period < 1 h
	laboratory determination weekly, if not more frequently	yes	^{131}I	4 mBq/m ³
aerosols	continuous measurement		all	4 Bq/m ³ during the measuring period < 1 h
	laboratory determination weekly, if not more frequently	yes	^{60}Co	1 mBq/m ³
			^{137}Cs	1 mBq/m ³
alpha activity	laboratory determination monthly, if not more frequently	yes	all	total activity 1 mBq/m ³
			^{241}Am	0.1 mBq/m ³
single significant nuclides	laboratory determination quarterly	yes	^{89}Sr and ^{90}Sr	combined activity 0.1 mBq/m ³
	laboratory determination monthly, if not more frequently		^3H	0.1 kBq/m ³
	laboratory determination monthly, if not more frequently		^{14}C	10 Bq/m ³

[2013-11-15]

A02. Table: Summary of the measurements of normal liquid releases from a nuclear power plant and examples of measurement detection limits that can be achieved or beaten at low total activities.

Release type	Measuring procedure	Redundancy	Radionuclide	Detection limit in release flow
gamma activity	continuous measurement	yes	significant	Detection limits clearly lower than the upper limit for gamma activity in the release line, e.g. 400 kBq/m ³
	laboratory determination release batch-specifically		significant	1 kBq/m ³
alpha activity	laboratory determination monthly		all	total activity 1 kBq/m ³
			²⁴¹ Am	10 Bq/m ³
single significant nuclides	laboratory determination quarterly		⁸⁹ Sr ja ⁹⁰ Sr	combined activity 0.2 kBq/m ³
	laboratory determination monthly		³ H	50 kBq/m

[2013-11-15]

8 References

1. Nuclear Energy Act (990/1987). [2019-03-15]
2. Nuclear Energy Decree (161/1988). [2013-11-15]
3. Radiation and Nuclear Authority Regulation on the Safety of a Nuclear Power Plant (STUK Y/1/2018). [2019-03-15]
4. Radiation and Nuclear Authority Regulation on the Safety of Disposal of Nuclear Waste (STUK Y/4/2018). [2019-03-15]
5. Radiation Act (859/2018) [2019-03-15]
6. Government Decree on Ionising Radiation (1034/2018) [2019-03-15]
7. Radiation Protection and Safety of Radiation Sources: International Basic Safety Standards, Interim Edition, General Safety Requirements Part 3, No. GSR Part 3, IAEA, Vienna 2014. [2019-03-15]
8. Safety of Nuclear Power Plants: Design Specific Safety Requirements, IAEA Safety Standards Series No. SSR-2/1, 2016. [2019-03-15]
9. Safety of Nuclear Power Plants: Commissioning and Operation Specific Safety Requirements, IAEA Safety Standards Series No. SSR-2/2, 2016. [2019-03-15]
10. Safety of Research Reactors, IAEA Safety Standards Series No. SSR-3, 2016. [2019-03-15]
11. Radiation Protection Aspects of Design for Nuclear Power Plants, IAEA Safety Standards Series No. NS-G-1.13, 2005. [2013-11-15]
12. Radiation Protection and Radioactive Waste Management in the Operation of Nuclear Power Plants, IAEA Safety Standard Series No. NS-G-2.7, 2002. [2013-11-15]
13. Radiation Protection and Radioactive Waste Management in the Design and Operation of Research Reactors, IAEA Safety Standard Series No. NS-G-4.6, 2008. [2019-03-15]
14. Programmes and Systems for Source and Environmental Radiation Monitoring, IAEA Safety Reports Series No. 64, 2010. [2013-11-15]
15. Council Directive 96/29/Euratom of 13 May 1996 laying down basic safety standards for the protection of the health of workers and the general public against the dangers arising from ionizing radiation. [2013-11-15]

16. The 2007 Recommendations of the International Commission on Radiological Protection, Annals of the ICRP, Publication 103, 2007. [2013-11-15]
17. Assessing Dose of the Representative Person for the Purpose of Radiation Protection of the Public and The Optimisation of Radiological Protection: Broadening the Process, Annals of the ICRP, Publication 101, 2006. [2013-11-15]
18. Regulatory Control of Radioactive Discharges to the Environment, Safety Standards Series No. WS-G-2.3, IAEA, Vienna 2000. [2013-11-15]
19. Environmental and Source Monitoring for Purposes of Radiation Protection, IAEA Safety Standard Series No. RS-G-1.8, 2005. [2013-11-15]
20. Effluent Release Options from Nuclear Installations, Technical Background and Regulatory Aspects, OECD/NEA, 2003. [2013-11-15]
21. Commission Recommendation no. 2010/635/Euratom of 11 October 2010 on the application of Article 37 of the Euratom Treaty. [2013-11-15]
22. Commission Recommendation on standardised information on radioactive airborne and liquid discharges into the environment from nuclear power reactors and reprocessing plants in normal operation, 2004/2/Euratom, 18 December 2003 and Corrigendum 6.1.2004. [2019-03-15]
23. ISO 2889:2010 Sampling airborne radioactive materials from the stacks and ducts of nuclear facilities. [2019-03-15]
24. IEC 60761:2002 Equipment for continuous monitoring of radioactivity in gaseous effluents. Parts 1–5. [2019-03-15]
25. IEC 60861:2006 Equipment for monitoring of radionuclides in liquid effluents and surface waters. [2019-03-15]
26. IEC 60768:2009 Nuclear Power Plants – Instrumentation important to safety – Equipment for continuous in-line or on-line monitoring of radioactivity in process streams for normal and incident conditions. [2019-03-15]
27. ISO 11929:2010 Determination of the characteristic limits (decision threshold, detection limit and limits of the confidence interval) for measurements of ionizing radiation – Fundamentals and application. [2019-03-15]

28. KTA 1503.1: Überwachung der Ableitung gasförmiger und an Schwebstoffen gebundener radioaktiver Stoffe, Teil 1: Überwachung der Ableitung radioaktiver Stoffe mit der Kaminfortluft bei bestimmungsgemäßem Betrieb, Fassung 2013-11, Sicherheitstechnische Regel des KTA, Deutschland. [2019-03-15]
29. KTA 1503.2: Überwachung der Ableitung gasförmiger und an Schwebstoffen gebundener radioaktiver Stoffe, Teil 2: Überwachung der Ableitung radioaktiver Stoffe mit der Kaminfortluft bei Störfällen, Fassung 2013-11, Sicherheitstechnische Regel des KTA, Deutschland. [2019-03-15]
30. KTA 1503.3: Überwachung der Ableitung gasförmiger und an Schwebstoffen gebundener radioaktiver Stoffe, Teil 3: Überwachung der nicht mit der Kaminfortluft abgeleiteten radioaktiven Stoffe, Fassung 2013-11, Sicherheitstechnische Regel des KTA, Deutschland. [2019-03-15]
31. KTA 1504: Überwachung der Ableitung radioaktiver Stoffe mit Wasser, Fassung 11/07, Sicherheitstechnische Regel des KTA, Deutschland. [2013-11-15]
32. WENRA Statement on Safety Objectives for New Nuclear Power Plants, WENRA, November 2010. [2013-11-15]
33. WENRA Reactor Safety Reference Levels for Existing Reactors, WENRA, September 2014. [2019-03-15]
34. Waste and Spent Fuel Storage Safety Reference Levels Report, WENRA Working Group on Waste and Decommissioning, February 2011. [2013-11-15]

Definitions

Representative person

Representative person shall refer to an individual in the population group most highly exposed to a given radiation source, whose radiation dose represents the doses received by such a population group (ICRP Publication 101). The term is equivalent to, and replaces, the previous term 'average member of the critical group'.

Effective dose

Effective dose shall refer to the weighted sum of the equivalent doses in tissues and organs exposed to radiation, where equivalent dose denotes the product of the mean energy imparted by radiation to tissue or to an organ, per unit mass, and a weighting factor specified for the radiation. Effective dose is presented as a formula in the Government Decree on Ionising Radiation (1034/2018).

Normal operating conditions

Normal operating conditions shall refer to the planned operation of a nuclear facility according to the operating procedures. Normal operating conditions also include testing, plant start-up and shutdown, maintenance and the replacement of nuclear fuel. (STUK Y/1/2018)

YVL Guides also use the term normal operation, which means the same as normal operating conditions.

Anticipated operational occurrence

Anticipated operational occurrence shall refer to such a deviation from normal operation that can be expected to occur once or several times during any period of a hundred operating years. (Nuclear Energy Decree 161/1988)

Postulated accident

Postulated accident shall refer to a deviation from normal operation which is assumed to occur less frequently than once over a span of one hundred operating years, excluding design extension conditions; and which the nuclear facility is required to withstand without sustaining severe fuel failure, even if individual components of systems important to safety are rendered out of operation due to servicing or faults. Postulated accidents are grouped into two classes on the basis of the frequency of their initiating events: a) Class 1 postulated accidents, which can be assumed to occur less frequently than once over a span of one hundred operating years, but at least once over a span of one thousand operating years; b) Class 2 postulated accidents,

which can be assumed to occur less frequently than once during any one thousand operating years. (Nuclear Energy Decree 161/1988)

Design extension condition

Design extension condition shall refer to:

- a. an accident where an anticipated operational occurrence or class 1 postulated accident involves a common cause failure in a system required to execute a safety function;
- b. an accident caused by a combination of failures identified as significant on the basis of a probabilistic risk assessment; or
- c. an accident caused by a rare external event and which the facility is required to withstand without severe fuel failure.

(Government Decree 717/2013)

Accident

Accident shall refer to postulated accidents, design extension conditions and severe accidents.

(Nuclear Energy Decree 161/1988)

Best available techniques

Best Available Techniques (BAT) shall refer to methods of production and treatment that are as efficient and advanced as possible and technologically and economically feasible, as well as methods of designing, constructing, maintenance and operation with which the pollution of the environment caused by activities can be prevented or most efficiently reduced. (Environmental Protection Act 86/2000)

Research reactor

Research reactor shall refer to a nuclear facility equipped with a nuclear reactor mainly used for the generation of neutron flux and ionising radiation for research and other purposes. (Nuclear Energy Act 990/1987)

Severe accident

Severe accident shall refer to an accident in which a considerable part of the fuel in a reactor or the spent fuel in a fuel pool or storage loses its original structure. (Nuclear Energy Decree 161/1988)

Severe reactor accident

Severe reactor accident shall refer to an accident in which a considerable part of the fuel in a reactor loses its original structure. (STUK Y/1/2018)

Annual dose

Annual dose shall refer to the sum of the effective dose arising from external radiation within the

period of one year, and of the committed effective dose from the intake of radioactive substances within the same period of time. (Nuclear Energy Decree 161/1988)

Nuclear waste

Nuclear waste shall refer to a) radioactive waste in the form of spent nuclear fuel or in some other form generated during or as a result of the use of nuclear energy and b) materials, objects and structures which, having become radioactive during or as a result of the use of nuclear energy and having been removed from use, require special measures owing to the danger posed by their radioactivity. (Nuclear Energy Act 990/1987)

Nuclear waste facility

Nuclear waste facility shall refer to a nuclear facility utilised for the encapsulation of spent nuclear fuel or the processing of other nuclear waste for disposal, and to a disposal facility for spent nuclear fuel or other nuclear waste; however, nuclear facility shall not refer to permanently closed facilities where nuclear waste has been placed in a manner approved as permanent by the Radiation and Nuclear Safety Authority. (Nuclear Energy Decree 161/1988)

Nuclear facility

Nuclear facility shall refer to the facilities used for the generation of nuclear energy, including research reactors, facilities for the large-scale disposal of nuclear waste, and facilities for the large-scale production, use, processing or storage of nuclear material and nuclear waste.

However, nuclear facility shall not refer to:

- a) mines or ore processing plants intended for the production of uranium or thorium, or premises and locations including their precincts where nuclear wastes from such facilities are stored or deposited for final disposal; or
- b) facilities and premises that have been permanently closed and where nuclear waste has been disposed in a manner approved as permanent by the Radiation and Nuclear Safety Authority; or
- c) premises or parts of a nuclear facility that have been decommissioned in a manner approved by the Radiation and Nuclear Safety Authority. (Nuclear Energy Act 990/1987)

Nuclear power plant

Nuclear power plant shall refer to a nuclear facility for the purpose of electricity or heat production, equipped with a nuclear reactor, or a complex consisting of nuclear power plant units and other related nuclear facilities located at the same plant site. (Nuclear Energy Act 990/1987).

Single failure

Single failure shall refer to a failure due to which a system, component or structure fails to deliver the required performance.

Single failure criterion

Single failure criterion (N+1) shall mean that it must be possible to perform a safety function even if any single component designed for the function fails.